



NOTES:

1. SEWERS SHALL BE KEPT REMOTE FROM WATER SUPPLY PIPING AND STRUCTURES. WHEREVER FEASIBLE, SEWERS SHOULD BE LAID AT A MINIMUM HORIZONTAL DISTANCE OF 10 FEET FROM WATER MAINS. IF LOCAL CONDITIONS PREVENT THIS, THE WATER MAIN SHOULD BE LAID IN A SEPARATE TRENCH, AND THE ELEVATIONS OF THE CROWN OF THE SEWER PLACED AT LEAST 18 INCHES BELOW THE INVERT OF THE WATER MAIN.
2. WHENEVER SEWERS MUST CROSS UNDER WATER MAINS, THE CROWN OF THE SEWER SHOULD BE PLACED A MINIMUM OF 18 INCHES BELOW THE INVERT OF THE WATER MAIN. IN ADDITION, THE WATER MAIN MUST BE CONSTRUCTED WITH ONE FULL LENGTH OF PIPE CENTERED ABOVE THE CROSSING. THE WATER PIPE SHALL HAVE MECHANICAL JOINTS FOR A MINIMUM DISTANCE OF 10 FEET ON EACH SIDE OF THE CROSSING.
3. WHEN IT IS IMPOSSIBLE TO OBTAIN HORIZONTAL OR VERTICAL SEPARATION AS STIPULATED ABOVE, BOTH THE WATER AND THE SEWER PIPING SHALL BE CONSTRUCTED SUCH THAT THE PIPE JOINTS ARE PLACED AS FAR AWAY FROM THE CROSSING AS POSSIBLE AND THE PIPE CROSSING SHALL BE ENCASED IN CONTROL DENSITY FILL FOR A DISTANCE OF 10 FEET ON ALL SIDES OF THE CROSSING.
4. SEE SECTION 3.3.1.2 PIPE INSTALLATION.

NOT TO SCALE



TOWN OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

SEWER CROSSING

DATE:
MAR. 2012

REV:
1

DETAIL NO.

S-3.5.0