



NOTES:

1. INSTALL VALVES AT INTERSECTION IN A CLUSTER CONFIGURATION. PROVIDE A MINIMUM 18" TO 24" MAXIMUM NIPPLE FROM FITTING TO VALVE.

NOT TO SCALE



CITY OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

VALVE LOCATION AT INTERSECTION

DATE:
APRIL 2018

REV:
2

DETAIL NO.

W-2.4.3