



**NOTES:**

1. ALL FITTINGS AND JOINTS IN LOWERING AREA TO BE RESTRAINED.
2. WHEN IT IS IMPOSSIBLE TO OBTAIN HORIZONTAL OR VERTICAL SEPARATION AS INDICATED IN THE DETAIL ABOVE, BOTH THE WATER AND THE SEWER SHOULD BE ENCASED IN CONTROL DENSITY FILL FOR A DISTANCE OF 10 FEET ON EITHER SIDE OF THE CROSSING.
3. ALL DUCTILE IRON PIPE AND FITTINGS SHALL BE WRAPPED WITH POLYETHYLENE ENCASEMENT WHEN CONTACTING CONTROL DENSITY FILL.

NOT TO SCALE



CITY OF FRAMINGHAM  
DEPARTMENT OF PUBLIC WORKS

**WATER MAIN LOWERING DETAIL**

DATE:  
MARCH 2010

REV:  
1

DETAIL NO.

**W-2.6.0**