



NOTES:

1. SEPARATE DOMESTIC AND FIRE SERVICES SHALL BE INSTALLED FROM THE BUILDING SERVICED TO THE PUBLIC WATER MAIN.
2. THE PROPERTY OWNER IS RESPONSIBLE FOR MAINTENANCE OF THE FIRE SERVICE FROM THE BUILDING SERVICED TO THE PUBLIC WATER MAIN.
3. SADDLE AND CORPORATION STOPS SHALL BE AWWA TAPER THREADS (MUELLER "CC") AS DESCRIBED IN AWWA STANDARD C800

NOT TO SCALE



CITY OF FRAMINGHAM
DEPARTMENT OF PUBLIC WORKS

TYPICAL FIRE SERVICE
FOR 1-1/2" TO 2"

DATE:
FEB. 2016

REV:
0

DETAIL NO.

W-2.1.2